



24-2510
Greenhouse at ATC
October 23, 2024

Addendum #1:

1. Is the interior electrical to be included? **Answer: Yes, interior electrical cost should be included in your bid.**
2. What is the power supply? **Answer: 120/240 single phase**
3. Are lights required? Is there a spec? **Answer: Yes, lights are required. We would like watertight pendant lights included (1 per 12')**
4. Are we to supply fire extinguisher? **Answer: Yes, fire extinguisher should be supplied.**
5. Are we to supply exit signs with remote head? **Answer: Yes, supply one exit sign per door.**
6. On the concrete slab does greenhouse supplier need to provide base reactions for Rock Hill architect to design the foundation or is the greenhouse supplier providing a slab design with SC registered engineer? **Answer: Please provide slab design with SC registered engineer.**
7. Do doors require locksets with removable cores? **Answer: Standard greenhouse doors that come with a basic lever lockset will be sufficient.**
8. Is special door hardware or any other features needed? **Answer: No, we are not requiring any special door hardware.**
9. Is Irrigation required? **Answer: Yes, we would like an irrigation system to include a 12-zone controller with a Dosmatic fertilizer injector. This needs to include all PVC, brass high-pressure regulator, filter, punch tool, manual valves and anything else required for a functioning, turn-key irrigation system.**
10. Is this project prevailing wage/ Davis bacon wage act? Does it require certified payrolls? **Answer: Yes, Davis Bacon wage act applies and certified payrolls will need to be provided.**

